



		Must Be Defined										Options			
		V	1		-										
<u>Down Cable Connection</u>															
	7-Pin Amphenol Connector	07													
**	14-Pin Amphenol Connector	14													
	6 Jaw Meter Base - A Config	6A													
	6 Jaw Meter Base - D Config	6D													
	6 Jaw Meter Base - E Config	6E													
	6 Jaw Meter Base - F Config	6F													
	Internal Connecting Terminal Block	NT													
<u>Supply Voltage</u>															
	Single Phase 120 VAC	1													
	Three Phase 120 VAC	3													
<u>SCADA Communications</u>															
	None	0													
	Fiber with ST Connectors	F													
	Serial with DB-9 Connector	S													
(Phoenix Conn)	Serial Direct Hardwired	D													
(Define if using PoE)	Ethernet	E													
<u>Temperature Sensor</u>															
	None	0													
	Temp	T													
<u>Current & Voltage Sensing</u>															
	None	0													
(0-10V)	LPCS	L													
	CT	C													
**	(0-10V) LPCS	B													
	(0-148V) PT	PT													
<u>Cap Bank Wye Neutral Sensing</u>															
	None	0													
	CT	C													
(120V NOM Secondary)	PT	P													
<u>Enclosure</u>															
	8x8 Carlon with Meter Base	0													
(NMK8V)	8x8 Carlon with Carlon Brackets	3													
(VBK02)	8x8 Carlon with Aluminum Brackets	5													
(NMK12V)	12x14 Carlon with Carlon Brackets	1													
(VBK01)	12x14 Carlon with Aluminum Brackets	2													
<u>Compatible with:</u>															
<u>DC Trip</u>															
Cooper ECS															
Joslyn VSV	Type 1	1													
ABB PSx5															
Cooper VCS-1S															
Maysteel UltraVac	Type 2	2													
<u>Options - Not Required</u>															
	(Dash)	-													
<u>Power over Ethernet</u>															
	12 VDC	E1													
(Passive)	24 VDC	E2													
	48 VDC	E4													
	IEEE 802.3af	E0													
<u>Staged Banks</u>															
	Configuration 1	21													
	Configuration 2	22													

** Three Phase VAr-Min ONLY